



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Commercial Innovations, Inc.
9105 Way Ave.
Cleveland, OH 44105-2197

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Commercial Innovations Built-Up Roofing Systems Over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 12-1101.04 and consists of pages 1 through 12.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 13-0930.05
Expiration Date: 12/03/16
Approval Date: 11/21/13
Page 1 of 12

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Built-Up Roofing
Material: Fiberglass/Asphalt
Deck Type: Concrete
Maximum Design Pressure: -375 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Viking AOB	36" x 72'	ASTM D2626	Asphalt coated organic base sheet.
Viking AB II	36" x 72' 75 lbs.	ASTM D4601 Type II	Type II, asphalt coated fiberglass base sheet.
Viking TG IV	36" x 180'	ASTM D4990 Type I	Coal Tar impregnated glass felt.
Viking TG VI	36" x 180'	ASTM D4990 Type I	Coal Tar impregnated glass felt.
Viking AG IV	36" x 180'; roll weight: 95 lbs.	ASTM D2178	Type IV asphalt impregnated glass felt for use in conventional and modified built-up roof systems.
Viking Poly Shield	40" x 324'	ASTM D5726	Polyester felt.
Viking AB Mastic	5 gallon	ASTM D4586	Trowel grade, asphalt based roofing mastic for use in repair and patching against leaks in built-up asphalt roofs.
Viking Sun Shield Fibered	5, 55 gallon	ASTM D2824 Type III	High solids, aluminized roof coating.
Viking CTP	70 lb. keg	Proprietary	Polymer modified coal tar pitch.
Millennium One Step Foamable Adhesive	1.5 liters	Proprietary	Polyurethane two component high rise insulation adhesive.



APPROVED INSULATIONS:**TABLE 2**

Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corporation
ENRGY 3, ENRGY 3 Plus	Polyisocyanurate foam insulation	Johns Manville Corp.
Fesco Board	Expanded perlite, insulation	Johns Manville Corp.
Retrofit Board	Perlite insulation board	Johns Manville Corp.
Multi-Max 3	Polyisocyanurate foam insulation	RMax Operating, LLC
DensDeck	Water resistant gypsum board	Georgia Pacific Gypsum LLC
Structodek High Density Fiberboard Roof Insulation	High Density wood fiber insulation board	Blue Ridge Fiberboard, Inc.
High Density Wood Fiberboard	Wood fiber insulation board	Generic

APPROVED FASTENERS:**TABLE 3**

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	N/A	N/A	N/A	N/A



EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Dynatech Engineering Corporation	#4530.05.95-1	TAS 114	05/31/95
Factory Mutual Research Corporation	IVOA7.AM	FM 4470	02/21/95
	1B4A7.AM		12/15/97
	4B4A9.AM		12/31/97
	0Y5A6.AM		09/08/97
	3D3A5.AM		09/15/98
	3004392		09/21/99
	0D9A0.AM		05/02/00
	3004907		05/16/00
	3009117		12/21/00
PRI Construction Mateerials Technologies	GRD-052-02-01	ASTM D 2178	10/31/11
	GRD-051-02-01	ASTM D 2178	10/31/11
	GRD-054-02-01	ASTM D 2626	11/17/11
Trinity ERD	4545.11.06	TAS 114-J	11/22/06
	4544.11.06	TAS 114-J	11/02/06
	G32700.09.11-1	ASTM D4601	09/16/11
	G37200.10.11-2	ASTM D 5726	10/18/11
	#4533.05.98-1-R1	TAS 114(J)	09/09/11
	G39620.07.12	ASTM D4990	07/02/12
	G37200.08.12-13-R2	ASTM D6162/D4798	09/26/13
Momentum Technologies, Inc.	EX11L5A	ASTM D2626/D4990	12/28/05



APPROVED ASSEMBLIES:

Membrane Type: BUR

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(1): All layers of insulation adhered with approved asphalt or adhesive.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners	Fastener Density/ft ²
ACFoam-II, ENRGY 3 (Insta-Stick or Hot Asphalt) Minimum 1" thick	N/A	N/A
ENRGY 3 Plus, Multi-Max 3 (Hot Asphalt only) Minimum 1" thick	N/A	N/A
Approved High Density Wood Fiberboard, Structodek High Density Fiberboard Roof Insulation (Hot Asphalt only) Minimum ½" thick	N/A	N/A
Structodek High Density Fiberboard Roof Insulation, Retrofit Board (Insta-Stick or Hot Asphalt) Minimum ½" thick	N/A	N/A
Fesco Board (Hot Asphalt only) Minimum ¾" thick	N/A	N/A
DensDeck (Insta-Stick or Hot Asphalt) Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft² or Insta-Stik Roofing Adhesive applied in continuous ¾" to 1" wide beads, 12" o.c. (primer optional). Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) Viking AB II adhered directly over the top layer of insulation with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: Two or more plies of Viking AB II, Viking AG IV or approved ASTM D 2178 type IV or VI ply sheet adhered with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required) Install the following:
1. 400 lbs./sq. gravel or 300 lbs./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lbs./sq. or in Viking CTP



Maximum Design Pressure:

- 45 psf. (See General Limitation #9)
- 90 psf. (for all Insta-Stick applications with asphalt applied membranes)
(See General Limitation #9)
- 145 psf. (for minimum 1.5" thick ENRGY 3 followed by an approved perlite insulation board, minimum ¾" thick, applied in hot asphalt with asphalt applied membranes) (See General Limitation #9)
- 237.5 psf. (for minimum 1.5" thick ENRGY 3 followed by minimum ¼" DensDeck or minimum ½" HD Fiberboard applied in hot asphalt with asphalt applied membranes.) (See General Limitation #9)

Membrane Type: BUR

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(2): One or more layers of insulation fully adhered to deck or spot mopped to optional anchor sheet with approved asphalt or adhesive.

All General and System Limitations apply.

Deck Primer: Deck is primed with ASTM D 41 primer.

Anchor Sheet: Install one ply of approved ASTM D 4897, Type II base sheet in a spot mopping of
(Optional) ASTM D 312, type III or type IV asphalt; 12" dia. circles, 24" o.c. at an application rate of 12 lbs./sq.

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners	Fastener Density/ft²
ACFoam-II, ENRGY 3, ENRGY 3 Plus, Multi-Max 3		
Minimum 1" thick	N/A	N/A
Approved High Density Wood Fiberboard, Structodek High Density Fiberboard Roof Insulation, Retrofit Board		
Minimum ½" thick	N/A	N/A
Fesco Board		
Minimum ¾" thick	N/A	N/A
DensDeck		
Minimum ¼" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of vapor barrier or insulation. All insulation shall be adhered to the vapor barrier or deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) Viking AB II adhered directly over the top layer of insulation with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: Two or more plies of Viking AB II, Viking AG IV or approved ASTM D 2178 type IV or VI ply sheet adhered with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required) Install the following:
 400 lbs./sq. gravel or 300 lbs./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lbs./sq. or in Viking CTP.

Maximum Design Pressure: -60 psf. (if insulation is fully adhered to deck) (See General Limitation #9.)
 -45 psf. (if optional spot mopped anchor sheet used) (See General Limitation #9.)

Membrane Type: BUR

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(3): One or more layers of insulation adhered with approved asphalt or adhesive.

All General and System Limitations apply.

Deck Primer: Deck is primed with ASTM D 41 primer.

One or more layers of any of the following insulations.

Base Insulation Layer (Optional):	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-II		
Minimum 1.5" thick	N/A	N/A
Top Insulation Layer:	Insulation Fasteners (Table 3)	Fastener Density/ft²
Structodek High Density Fiberboard		
Minimum 0.5" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft², or in ½" – ¾" wide beads of Millennium One Step Foamable Adhesive spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

System 1:	Base/Ply Sheet:	Three to five plies Viking TG IV/Viking TG VI or Viking Poly Shield adhered in full mopping of Viking CTP or approved Type I or Type III Coal Tar Pitch at a rate of 30 lbs./sq.
System 2:	Base/Ply Sheet:	One ply Viking AOB, Viking AB II adhered in full mopping of approved asphalt at a rate of 25 lbs./sq.
	Cap Sheet:	Two to four plies Viking TG IV, Viking TG VI or Viking Poly Shield adhered in full mopping of Viking CTP or approved Type I or Type III Coal Tar Pitch at a rate of 30 lbs./sq.

Surfacing: (Required) Install the following:

1. 400 lbs./sq. gravel or 300 lbs./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lbs./sq. or in Viking CTP.

Maximum Design Pressure:

- 82.5 psf. (no base insulation, coverboard in Millennium One Step Foamable Adhesive) (See General Limitation #9)
- 127.5 psf. (base insulation in Millennium One Step Foamable Adhesive, coverboard in asphalt) (See General Limitation #9)
- 270 psf. (roof cover in coal tar or hot asphalt) (See General Limitation #9)

Membrane Type: BUR

Deck Type 3: Concrete Decks, Non-Insulated

Deck Description: 2500 psi concrete plank

System Type F(1): Roof cover adhered with approved asphalt or adhesive.

All General and System Limitations apply.

Base Sheet: (Optional) Viking AB II adhered directly over the top layer of insulation with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: Two or more plies of Viking AB II, Viking AG IV or approved ASTM D 2178 type IV or VI ply sheet adhered with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required) Install one following:
1. 400 lbs./sq. gravel or 300 lbs./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lbs./sq. or in Viking CTP

Maximum Design

Pressure: -375 psf. (See General Limitation #9.)

Membrane Type: BUR

Deck Type 3: Concrete Decks, Non-Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(2) Roof cover adhered to spot mopped base sheet with approved asphalt or adhesive.

All General and System Limitations apply.

Base Sheet: Install one ply of approved ASTM D 4897, Type II base sheet over the primed concrete deck in a spot mopping of ASTM D 312, type III or type IV asphalt; 12" dia. circles, 24" o.c. at an application rate of 12 lbs./sq.

Ply Sheet: Two or more plies of Viking AB II, Viking AG IV or approved ASTM D 2178 type IV or VI ply sheet adhered with a full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required) Install one following:
1. 400 lbs./sq. gravel or 300 lbs./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lbs./sq. or in Viking CTP

Maximum Design Pressure: -45 psf. (See General Limitation #9.)

Membrane Type: BUR

Deck Type 3I: Concrete Decks, Non-Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(3): Base sheet adhered with approved asphalt or adhesive.

All General and System Limitations apply.

Deck Primer: Deck is primed with ASTM D 41 primer.

System 1: Base/Ply Sheet: Three to five plies Viking TG IV, Viking TG VI or Viking Poly Shield adhered in full mopping of Viking CTP or approved Type I or Type III Coal Tar Pitch at a rate of 30 lbs./sq.

System 2: Base/Ply Sheet: One ply Viking AOB, Viking AB II adhered in full mopping of approved asphalt at a rate of 25 lbs./sq.

Cap Sheet: Two to four plies Viking TG IV, Viking TG VI or Viking Poly Shield adhered in full mopping of Viking CTP or approved Type I or Type III Coal Tar Pitch at a rate of 30 lbs./sq.

Surfacing: (Required) Install the following:
1. 400 lbs./sq. gravel or 300 lbs./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lbs./sq. or in Viking CTP

Maximum Design Pressure: -270 psf. (roof cover in coal tar or hot asphalt) (See General Limitation #9)

CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 13-0930.05
Expiration Date: 12/03/16
Approval Date: 11/21/13
Page 12 of 12